

OFFICE OF THE JUNIOR CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT LABORATORY, KARALI  
CHEMICAL EXAMINATION REPORT

NO. LAB/Tech. (Chem)/2018-19/ 361

Date:- 03/01/19

To,  
Sh. Devanand Vogula  
Veena Memorial Sen. Sec. School  
Karauli


Dist.: KARALI

Ref: Your :-Nil

Date of Receipt:-02.01.2019

Source	RO	
Source Location	Veena Memorial Sen. Sec. School Karauli	
Habitation		
Village/Town/Panchayat	Karauli	
Village code no.		
Date of Collection	01.01.2019	
Date of Examination	03.01.2019	
Lab sample No.	P-9	
1	pH	7.2
2	Turbidity(NTU)	-
3	Colour	-
4	Odour	-
5	Temperature(*C)	-
6	Total Alkalinity(as CaCO <sub>3</sub> )	80
7	Total Hardness (as CaCO <sub>3</sub> )	140
8	Calcium Hardness (as CaCO <sub>3</sub> )	-
9	Magnesium Hardness (as CaCO <sub>3</sub> )	-
10	Chloride (as Cl)	70
11	Sulphate (as SO <sub>4</sub> -2)	-
12	Nitrite(as NO <sub>2</sub> )	-
13	Nitrites(as NO <sub>3</sub> )	34
14	Fluoride (as F)	0.12
15	Total Dissolved Solids	350

Remarks: SAMPLE NOT COLLECTED BY THIS LAB (water is potable)

  
Junior Chemist  
PHED Lab. KARALI

  
Principal  
Veena Memorial Sr. Sec. School  
Karauli (Raj.)

  
Secretary  
Veena Memorial Sr. Sec. School  
Karauli (Raj.)

## कार्यालय नगरपरिषद, करौली (राज0)

क्रमांक: 2527

दिनांक: 10-1-19

### प्रमाण-पत्र

प्रमाणित किया जाता है कि वीणा मैमोरियल सेवा सोसायटी द्वारा संचालित विद्यालय वीणा मैमोरियल सीनियर सैकण्डरी स्कूल, वीणा कैम्पस करौली में स्थित है जिसमें जल संग्रहण टैंक एवं शौचायलयों की साफ सफाई की उपयुक्त व्यवस्था है। विद्यालय भवन में छात्र-छात्राओं हेतु शुद्ध पेयजल एवं भवन में जल निकासी की भी उपयुक्त व्यवस्था है।



आयुक्त

नगरपरिषद, करौली



Principal  
Veena Memorial Sr. Sec. School  
Karauli (Raj.)



School Head  
Veena Memorial Sr. Sec. School  
Karauli (Raj.)